

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:10 pm

PWS ID: UTAH14011 **Name:** SCIPIO TOWN

Legal Contact: SCIPIO **Rating:** Approved
THOMAS C MEMMOTT **Rating Date:** 05/29/1987

Address: BOX 560066 **Activity Status:** Active
SCIPIO, UT 84656

Phone Number: 435-758-2605

City Served (Area):

County: MILLARD COUNTY

System Type: Community **Last Inv Update:** 06/09/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 07/28/2008 **Total Dsgn Cap:**
Population: 300 **Surveyor:** JOHN H OAKESON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	MEMMOTT, THOMAS C		435-758-2676	435-979-5346	tom_memmott@blm.gov

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	177
Combined	Unknown	0	99
Commercial	Unknown	0	6
			282 Total Svc Connections

Storage

Total Storage: 450,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	#1 - EAST ST001	Ground	225,000 GAL	Concrete		A	
ST002	#2 - WEST ST002	Ground	225,000 GAL	Concrete		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	5 MILE SPRING CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	5 MILE SOUTH OF TOWN SF	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	OLD TOWN WELL	Inactive	WL	8	300 GPM	200 GPM	Yes	GW	Other		

*Reports measured flow for wells, approved design capacity for all other sources.